

WILLIAMSTOWN BOROUGH AUTHORITY

September 10, 2010

Williamstown Borough Authority met Wednesday, September 10, 2010 in Council Chambers; Members, Chairman Dennis English, Vice Chairman C.W. Croft Sr., Scott Slough, David Neidlinger, and Jack Herb were present. Timothy Kessinger and Daniel Huddleson were absent. Also attending were Secretary/Treasurer Amy Rexroth, Sewer Plant Manager Roy Miller and Engineer Bob Reisinger. Citizens present were Dane Williard, Mark Falcone, and Mark Salak.

Chairman Dennis English called the meeting to order at 3.30PM.

The purpose of this special meeting is about a pier failure at the Sewer Plant.

Discussion took place with Mark Falcone representing Dutchland (manufacturer) and Mark Salak representing Quandel (general contractor) of what went wrong with this one pier and what is the solution to fix the problem.

Herb would like to retract his motion that was made on September 1, 2010 requiring Quandel to replace the pier. Motion died with no second.

Slough made a motion to have the pier replaced with a new pier. Motion died with no second.

A motion was made by Croft Sr. and Neidlinger to repair the existing failed pier with a minimum of a 4 10X10 stainless steel angle brackets, pinned to the pier in way that one side does not interfere with the other and pinned to the floor of the tank. In addition to the brackets there will be a curb poured all around said pier and will be 12" high. The Authority wants an additional 5 year warranty on the repaired pier. All remaining piers will be curbed and barracked with angles as specified in documents handed to the Authority. All were in favor. Slough stated he will go back to original motion to have the pier replaced if all conditions were not met. (Documents will be attached to the official minutes.)

A motion was made by Croft Sr. and Slough to adjourn the meeting at 4:20PM.